



# EYEWASH INSPECTION LOG

Emergency eyewash stations, capable of providing a 15-minute flush of tepid water, must be available wherever there is a possibility of exposure to hazardous chemicals or biologicals. Eyewash units should be located within 10 seconds (~55 ft) of potential exposure areas, clearly marked, free of any obstructions, and checked weekly. Weekly checks must be documented.

- Access to the eyewash is free of any obstructions.
- Nozzle is clear of debris or build-up.
- Eyewash is activated over the sink and flushed continuous for 1-3 minutes or until water is clear (no rust or dirt).
- Nozzle covers are in place and open once the eyewash is activated.
- Water temperature is tepid/lukewarm.
- Water pressure is adequate, no leaks.

| Month            | Date and initial to verify above items have been checked |        |        |        |             | Noted Issues* |
|------------------|--|--------|--------|--------|-------------|---------------|
| <b>January</b>   | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>February</b>  | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>March</b>     | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>April</b>     | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>May</b>       | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>June</b>      | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>July</b>      | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>August</b>    | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>September</b> | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>October</b>   | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>November</b>  | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |
| <b>December</b>  | Week 1   | Week 2 | Week 3 | Week 4 | Week 5 / NA |               |

\*Report issues to Facilities Management, if necessary, alert lab personnel of the issue/post appropriate signage.